

FUSCO

ENGINEERING &
LAND SURVEYING, D.P.C.



233 East Main Street
Middletown, NY 10940

Phone: (845)344-5863
Fax: (845)956-5865

Consulting Engineers

Alfred A. Fusco, Jr.
P.E. Principal

Alfred A. Fusco, III
General Manager

January 30, 2025

Solomon Weiss, Planning Board Chairman
Village of South Blooming Grove
811 NYS Route 208
Monroe, NY 10940

Project: 822 Route 208
SBL: 209-1-1
Material Reviewed: Plan prepared by Kirk Rother, PE dated 11/1/24
Our File #: SBG-188

Dear Solomon Weiss,

We have reviewed the material submitted and offer the following comments:


1. Need application and receipt for paid fees.
2. SEAF with DEC mapper. <https://gisservices.dec.ny.gov/eafmapper/>
3. Certified survey and topography stamp by design professional.
4. Sprinklers are required 4" DIP minimum.
5. Provide fire department connection details.
6. SWPPP required.
7. Level spreader at discharge from overflow structure.
8. Infiltration testing to be witnessed by the Village Engineer.
9. Show concrete washout station.
10. Provide wash at stabilized base.
11. Provide snow storage area.

12. Cloud all revisions.

13. All future submission packages are to be submitted to aafjr@fuscoengineering.com as well as the Village.

Please advise if you have any questions.

Very truly yours,



Alfred A. Fusco, Jr., P.E.
Fusco Engineering &
Land Surveying, D.P.C.

Cc: Tom Shepstone, VOSBG
Kerry Dougherty, Clerk, VOSBG
Issac Ekstein, VOSBG
Joel Stern, VOSBG
Efrain Biaz, FE&LS
Todd Maurizzio, FE&LS
Alfred A. Fusco, Jr., P.E., FE&LS
Kirk Rother, P.E.